


(NOTE: NOT ALL SYMBOLS SHOWN ARE USED ON DRAWINGS)

| SYMBOL | DESCRIPTION |
|-----------|--|
| | 4' OR 8' FLUORESCENT LIGHT FIXTURE |
| | LIGHT FIXTURE CONNECTED TO NIGHT LIGHT/EMERGENCY CIRCUIT OR EQUIPPED W/ INTEGRAL BATTERY PACK |
| | 4' OR 8' FLUORESCENT STRIP LIGHT FIXTURE |
| | 4' OR 8' EMERGENCY FLUORESCENT STRIP LIGHT FIXTURE |
| | WALL MOUNTED LIGHT FIXTURE |
| | MOTOR RATED SWITCH WITH OVERLOADS. MOUNT 48" A.F.F. |
| | DUPLEX RECEPTACLE, +18" AFF TO CENTERLINE-UON |
| | DUPLEX CONVENIENCE RECEPTACLE WITH INTERNAL GROUND FAULT FAULT CIRCUIT PROTECTION. |
| | WEATHERPROOF DUPLEX RECEPTACLE. |
| | EQUIPMENT CONNECTION. (CONTRACTOR SHALL PROVIDE ALL WIRING CONDUIT, MOTOR STARTER, OVERCURRENT PROTECTIVE DEVICES, DISCONNECT SWITCH, ETC. REQUIRED TO CONNECT EQUIPMENT ELECTRICALLY. EQUIPMENT MAY BE PROVIDED BY DIVISION 16 OR OTHERS) |
| | TRANSFORMER (SHOWN TO SCALE ON PLAN) |
| | DISCONNECT SWITCH |
| | DISCONNECT SWITCH, FUSED |
| 100/100/3 | FDS SIZE/FUSE SIZE/NUMBER OF POLES |
| | GROUND |
| | ELECTRICAL PANELBOARD (480/277 VOLT). |
| | ELECTRICAL PANELBOARD (208/120 VOLT). |
| | TIME CLOCK, RATING AS INDICATED. MOUNT 54" A.F.F. |
| | PHOTO-ELECTRIC CONTROL. MOUNT ABOVE ROOF PARAPET LINE FACING NORTH. |
| | CIRCUIT WITH 2#12, 1#12G, CONDUCTORS AND 1/2" C. IS REQUIRED WHEN NO MARKS ARE SHOWN UON |
| | CONDUIT STUBBED UP AND CAPPED |
| | HOMERUN TO PANEL A, CIRCUIT 1 |
| | CIRCUIT HOMERUN - THREE CIRCUITS INDICATED |
| | DATA OUTLET. MOUNT 15" A.F.F. UNLESS U.O.N. BY DRAWINGS OR SPECIFICATIONS PROVIDE A 4" SQ. BOX W/ SINGLE DEVICE PLASTER RING, 3/4" E.C. WITH PULLSTRING STUBBED INTO NEAREST ACCESSIBLE CEILING. |

| ABBREVIATION | DESCRIPTION |
|--------------|-------------------------------------|
| A | AMPERES OR TRIP AMPERES |
| AFF | ABOVE FINISHED FLOOR |
| AIC | AMPERE INTERRUPTING CAPACITY |
| ARCH | ARCHITECT |
| AT | AMPERE TRIP |
| ATS | AUTOMATIC TRANSFER SWITCH |
| AWG | AMERICAN WIRE GAUGE |
| CB | CIRCUIT BREAKER |
| CKT | CIRCUIT |
| CLG | CEILING |
| CT | CURRENT TRANSFORMER |
| EXIST. | EXISTING |
| FACP | FIRE ALARM CONTROL PANEL |
| FCU | FAN COIL UNIT |
| FLA | FULL LOAD AMPS |
| GALV | GALVANIZED |
| GFCI | GROUND FAULT CIRCUIT INTERRUPTER |
| Kcmil | 1000 CIRCULAR MILS |
| KV | KILOVOLTS (THOUSAND VOLTS) |
| KVA | KILOVOLTS-AMPS (THOUSAND VOLT-AMPS) |
| KW | KILOWATT (THOUSAND WATTS) |
| MCA | MINIMUM CIRCUIT AMPS |
| MCB | MAIN CIRCUIT BREAKER |
| MH | MANHOLE |
| MLO | MAIN LUGS ONLY |
| NC | NORMALLY CLOSED |
| NEC | NATIONAL ELECTRIC CODE |
| OE | OVERHEAD ELECTRIC |
| PB | PULL BOX |
| PE | PHOTO ELECTRIC |
| RECEPT | RECEPTACLE |
| RLA | RATED LOAD AMPS |
| TC | TIME CLOCK |
| TYP | TYPICAL |
| UE | UNDERGROUND ELECTRIC |
| UH | UNIT HEATER |
| UL | UNDERWRITER'S LABORATORY |
| UON | UNLESS OTHERWISE NOTED |
| V | VOLTS |
| VA | VOLT AMPERES |
| WP | WATER PROOF |
| WR | WEATHER RESISTANCE |
| XFMR | TRANSFORMER |

| LIGHTING SCHEDULE | | | | | |
|---|---|-------|-----------------------------|--------------|-------------|
| NOTE: INSTALL THE FOLLOWING LIGHTING FIXTURES AND COMPONENTS. ELECTRICAL SUBCONTRACTOR SHALL PROVIDE FRAME-IN KITS AND ACCESSORIES AS REQUIRED. | | | | | |
| TYPE | MANUFACTURER & CATALOG NO. | VOLTS | LAMP TYPE | MOUNTING | REMARKS |
| A | WALL SCONCE COOPER - SHAPER #674-31-WP-T5/2/21-120-BM | 120V | 2-21 WATT T5 | SURFACE WALL | |
| B | WALL PACK COOPER - MCGRAW EDISON #MT-42-CF-120-25-BZ-F | 120V | 1-42 WATT CFL | SURFACE WALL | |
| C | PARKING LOT AREA LIGHT & POLE COMBO COOPER - LUMARK #PFT-1-40-23-P-20-9 | 208V | 1-400 WATT PULSE START M.H. | POLE | 20'-0" POLE |

| GENERAL NOTES: | |
|----------------|--|
| 1. | ALL CONDUCTORS SHALL BE COPPER, #12 AWG MINIMUM, UNLESS OTHERWISE NOTED. REFER TO SECTION 260519 FOR VOLTAGE DROP LIMITATIONS |
| 2. | ALL CONDUIT SHALL BE 1/2" MINIMUM, UNLESS OTHERWISE NOTED. MINIMUM CONDUIT SIZES FOR TELECOMMUNICATION SHALL BE 1". |
| 3. | CONFIRM COMPATIBILITY BETWEEN CEILING TYPES, DEFINED IN THE ARCHITECTURAL ROOM FINISH SCHEDULES & THE LIGHT FIXTURE TRIM AND MOUNTING HARDWARE DEFINED IN THE LIGHTING FIXTURE SCHEDULE, PRIOR TO PURCHASING LIGHT FIXTURES. |
| 4. | FOR EXACT LOCATION OF MECH. AND PLUMBING EQUIP., REFER TO MECH. AND PLUMBING DRAWINGS. |
| 5. | FURNISH AND INSTALL IN-LINE FUSES FOR ALL UNSWITCHED LIGHT FIXTURES AND NIGHT LIGHT (UL) DESIGNATED LIGHT FIXTURES. |



1 TELEPHONE SERVICE DETAIL
SCALE: NOT TO SCALE



GARY SHAW ARCHITECTS

design + planning


1821 margaret st.
austin, texas 78704
off: (512)416-8471
fax: (512)416-8478



KENEDY RETAIL

131 BUSINESS PARK DRIVE
KENEDY, TEXAS 78119

| | |
|-------------|----------|
| project no. | 167.1201 |
| date | 11/19/12 |
| scale: | NO SCALE |
| revisions | |



Engineering, LLC
MEP CONSULTING ENGINEERING
203 E. Main Street, Suite 204 - Round Rock - TX 78664
www.AYSeng.com - 512-961-6835
TDP: Form-10298

ELECTRICAL LEGEND,
SCHEDULE & DETAILS
sheet no.

E1.0